

# TEST ATTESTATION

Contract No. 1261/2017 - BF 18.09.2017  
WIM/PIK

Customer: dormakaba Austria GmbH  
Ulrich-Bremi-Straße 2  
AT-3130 Herzogenburg

Subject: Assessment of mortise locks type 170 with modified construction according to EN 12209, version: December 2003 + AC December 2005

Result: According to expert's report No. 1261/2017 it is confirmed, that the mortise locks type 170 in different versions had been tested according to EN 12209 and the following classification was reached:

Type	1 Category of use	2 Durability and load on latch-bolt	3 Door mass and closing force	4 Suitability for use on fire / smoke doors <sup>1)</sup>	5 Safety	6 Corrosion resistance and temperature	7 Security and drill resistance	8 Field of door application	9 Type of key operation and locking	10 Type of spindle operation	11 Key identification
<b>170.W Z</b>	<b>3</b>	<b>M</b>	<b>5</b>	<b>1</b>	<b>0</b>	<b>E</b>	<b>1</b>	<b>B</b>	<b>C</b>	<b>2</b>	<b>0</b>
<b>170.PZ</b>	<b>3</b>	<b>M</b>	<b>5</b>	<b>1</b>	<b>0</b>	<b>A</b>	<b>1</b>	<b>B</b>	<b>C</b>	<b>2</b>	<b>0</b>
<b>170.W C</b>	<b>3</b>	<b>M</b>	<b>5</b>	<b>1</b>	<b>0</b>	<b>A</b>	<b>1</b>	<b>B</b>	<b>G</b>	<b>2</b>	<b>0</b>
<b>170.F A</b>	<b>3</b>	<b>M</b>	<b>5</b>	<b>1</b>	<b>0</b>	<b>A</b>	<b>--</b>	<b>B</b>	<b>--</b>	<b>2</b>	<b>0</b>
<b>170.RI</b>	<b>--</b>	<b>--</b>	<b>--</b>	<b>0</b>	<b>0</b>	<b>A</b>	<b>1</b>	<b>B</b>	<b>C</b>	<b>--</b>	<b>0</b>

<sup>1)</sup> latch with falling bevel 6° for 30 minutes fire resistant doors, latch without falling bevel for 120 minutes fire resistant doors

Period of validity: --

  
DI Martin Wieser  
Technical consultant

HOLZFORSCHUNG AUSTRIA



  
DI (FH) Jens Schöne

In case of dispute the original German version prevails. This translation is for information purposes only.